

# Compliance Statement

No. 2019-272

## Screened Channel, Class E<sub>A</sub>

### Company

AZENN  
23, rue du champ Morin  
ZA de la Gautrais  
35360 Montauban-de-Bretagne  
France

### Channel Identification (2 connector model)

#### Ekivalan Systems Installation cables:

Ref. MCC6AUFTP4PL – Cat. 6A U/FTP 4 pair LSZH grey cable  
Ref. MCC6AUFTP8PL – Cat. 6A U/FTP 2x4 pair LSZH grey cable

#### Ekivalan Systems Patch Cords:

Ref. MCPC6ASFTPLG 5,00 – 5 meter patch cord LSZH Cat. 6A

#### Ekivalan Systems RJ45 Jacks:

Ref. MCJ6AST – RJ45 shielded Cat. 6A toolless jack

#### Ekivalan Systems 19" 24 port Panel:

Ref. MCPP241UMB – 24 port / 1 U black panel with rear cable holder  
Ref. MCPP241UM+AB – 24 port / 1U black panel with rear cable holder and quick cable attachments

#### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

#### Technical report

T924854-05, DANAK-19/20081

#### EC Cabling product ID


5703

#### CS valid until

1 March 2020

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 3 April 2019



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

