

Compliance Statement

No. 2018-182

Screened Channel, Class E_A

Company

AZENN
23, rue du champs Morin
ZA de la Gautrais
35360 Montauban-de-Bretagne
France

Channel Identification (2 connector model)

MASTERCABLING Installation cables:

Ref. MCC6AUFTP4PL – Cat. 6A U/FTP 4 pair LSZH grey cable
Ref. MCC6AUFTP8PL – Cat. 6A U/FTP 2x4 pair LSZH grey cable

MASTERCABLING Patch Cords:

Ref. MCPC6ASFTPLG 5,00 – 5 meter patch cord LSZH Cat. 6A

MASTERCABLING RJ45 Jacks:

Ref. MCJ6AST – RJ45 shielded Cat. 6A toolless jack

MASTERCABLING 19" 24 port Panel:

Ref. MCP241UMB – 24 port / 1 U black panel with rear cable holder

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2011 / EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

T823332-01, DANAK-19/18874

EC Cabling product ID


5703

CS valid until

1 March 2019

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 19 February 2018



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

